DRAFT - FOR DISCUSSION PUROPSES ONLY

Summary of June 2013 Pogo Mine Incinerator Source Test Results and NSPS Subpart CCCC Table 8 Standards

		Test Results (3-Run Average)						Calculated Results ^a			Subpart CCCC Table 8	
Method	Pollutant	lb/hr	lb/dscf	ppmvd	ug/dscm	ng/dscm	O ₂ (%)	mg/dscm	ng/dscm	ppmvd ^c	Emission Limit ^d	
RM5	PM	0.20	4.13E-06	-	-		10.66	90	-	-	270	mg/dscm
RM26A	HCl	0.66	1.33E-05	-	-		10.66	-	-	191	200	ppmvd
RM29	Cd Pb Hg	3.98E-05 2.22E-04 7.79E-06	8.40E-10 4.57E-09 1.66E-10	- - -	32.25 197.08 2.67		10.67 10.67 10.67	0.044 0.27 0.0036	- - -	- -	0.67 2.0 0.0035	mg/dscm mg/dscm mg/dscm
RM23	D/F	-	-	-	-	2.285 0.1154	NA ^b	-	2.285 0.1154	-	1800 31	ng/dscm Total Mass ng/dscm TEQ ^e
RM10	СО	0.005	-	1.3	-		10.7	-	-	1.8	13	ppmvd
RM7E	NOx	0.42	-	69.7	-		10.7	-	-	95	170	ppmvd
RM6C	SO_2	0.19	-	22.2	-		10.7	-	-	30	1.2	ppmvd

 $^{^{\}mathrm{a}}\mathrm{Test}$ results were converted to 7% O_{2} and into units of the applicable emission limits

 $^{^{\}rm b}\!{\rm D/F}$ results are reported in terms of ng/dscm at 7% ${\rm O_2}$ - no conversions needed

 $^{^{}c}HCl$ was converted from lb/dscf to ppmvd based on MW = 36.46 lb/lbmol, and standard molar volume of an ideal gas = 385.55 dscf/lbmol (i.e., std temp = 20 ^{o}C)

CO, NOx and SO₂ were not converted (test results are provided in ppmvd)

 $[^]d Emission$ limits are measured at 7% $\mathrm{O}_2,$ dry basis at standard conditions

^eSubpart CCCC requires compliance with *either* the Total Mass Basis limit or the Toxic Equivalency Basis limit